

REV. 6
 PART NO. 91450-*FTD-1

TIME DELAY RANGE

OPTION CODE

1FTD = 1 SEC
 2FTD = 2 SEC
 3FTD = 5 SEC
 4FTD = 10 SEC
 5FTD = 20 SEC
 6FTD = 50 SEC
 7FTD = 100 SEC
 8FTD = 200 SEC
 9FTD = 500 SEC

1GP, 2GP, 5GP, 6GP DELAY OCCURS ON ALARM ONLY. DELAY ON TEST OR WHEN POINT RETURNS TO NORMAL IS APPROX. 3mS.
 7GP, 8GP, 10GP EQUAL DELAY OCCURS ON ALARM, TEST AND WHEN POINT RETURNS TO NORMAL.

DELAYS FROM 1 TO 50 SEC. ARE ±12% OF STATED VALUE, DELAYS FROM 100 TO 500 SEC. ARE ±20% OF STATED VALUE.

2 FTDA = 2 SEC
 3 FTDA = 3 SEC
 5 FTDA = 10 SEC

12FTD = 2 mS
 13FTD = 5 mS
 14FTD = 10 mS
 15FTD = 20 mS
 16FTD = 50 mS
 17FTD = 100 mS
 18FTD = 200 mS
 19FTD = 500 mS

EQUAL DELAY OCCURS ON ALARM, TEST AND WHEN POINT RETURNS TO NORMAL.

DELAYS ARE ALL ±12.5% OF STATED VALUE

NOTES:

- 1 ▷ 20mS DELAY IS STANDARD. (NO OPTION CODE REQUIRED).
- 2 ▷ TEST MAY BE INITIATED BY MOMENTARY OR MAINTAINED PUSHBUTTON OPERATION. TEST WILL OCCUR AFTER THE INPUT TIME DELAY INTERVAL.
3. IF THE ACK PUSHBUTTON IS OPERATED BEFORE THE TEST CYCLE IS COMPLETE, ELECTRONIC OR RELAY OUTPUT MODES 4 AND 5 WILL ACTUATE UNTIL THE TEST CYCLE IS COMPLETE.
4. SEE SEQUENCE CARD MODEL NUMBER FOR OPTION CODE ORDERED.
5. REFERENCE DRAWINGS 91900-2 & 92900-2.

91450-_FTD-1-06-01.dwg

SYM	REVISION	DATE	BY	CH.	RESTRICTED, CONFIDENTIAL DOCUMENT THIS DRAWING AND ALL INFORMATION SHOWN HEREON ARE THE EXCLUSIVE PROPERTY OF AMETEK / PANALARM AND ARE SUBMITTED ONLY ON A CONFIDENTIAL BASIS. THE RECIPIENT AGREES NOT TO REPRODUCE THE DRAWING, TO RETURN IT UPON REQUEST, AND THAT NO DISCLOSURE OF THE DRAWING OR THE INFORMATION SHOWN HEREON WILL BE MADE TO A THIRD PARTY WITHOUT PRIOR WRITTEN CONSENT FROM AMETEK / PANALARM			AMETEK PANALARM, 1725 WESTERN DRIVE, WEST CHICAGO, IL. 60185						
06	ECO# 6580, REDRAWN	10/05/01	SK	MAL	DR.	RSP / SK	DATE	07/29/83	CH.	AHD 07/29/83	APP.	AHD 07/29/83		
05	11872	06/15/01	SK	MAL	SCALE	NONE	TOLERANCES NOT SPECIFIED	DECIMAL	±.005"	FRACTIONAL	±.010"	ANGULAR	±1'	
04	11589	01/23/95	AD	AHD	DRAWING NAME			SPECIFICATIONS FOR FIXED TIME DELAY OPTION			PART NO.	91450-*FTD-1	REV.	6
03	7099-92	10/16/90	SK	JE										
02	10062	02/15/89	SK	PG										
01	8900-37	02/07/84	JE	RCV										